

# **Certificate of Compliance**

Certificate:

70214162

Master Contract: 274708

Project:

70214162

Date Issued: February 11, 2019

Issued to:

TE.CO. TECNOLOGIA COMMERCIALE S.p.A.

Via Achille Grandi, 1

Castel Maggiore, Bologna 40013

Italy

Attention:

The products listed below are eligible to bear the CSA Mark shown



Lina Bartolotta

Issued by:

Lina Bartolotta

## **PRODUCTS**

CLASS 5835 01 - WIRES Equipment

Max temperature rating 150C: SEWF-1, SEWF-2.

Max temperature rating 200C: SEW-1, SEWF-1, SEW-2, SEWF-2.

Note: Insulation in light colours only.

TEW, single conductor construction, 105C, 600V, FT1.



Certificate: 70214162

Master Contract: 274708

**Project:** 70214162

**Date Issued:** February 11, 2019

### CLASS 5851 01 - WIRES Appliance

AWM Class	AWM Group	Temp Deg C	Max Volt	Jacket Type/ Min Avg. Thick (mm)	Coverings Type/ Min Avg. Thick (mm)	Size Range AWG	Insul. Type/ Min Avg. Thick (mm)	Notes
SINGLE-CONDUCTOR:								
I	A/B	150, 200	300, 600	-	Glass fibre	32-12 10 8-2 1-4/0	SiR/0.76 /1.14 /1.52 /2.03	1,3,4
I	A	150, 200	300	_	Glass fibre	32-16	SiR/0.38	1,3,5
I	A/B	60, 80, 90, 105	300, 600, 1000	=	-	24- 1000kcmil	PVC/0.38 PVC/0.76 PVC/0.76	1,4
MULTI-CONDUCTOR/ROUND:								
I/II	A/B	150, 200	600	SiR/1, 14	-	24-12 10 8-2 1-4/0	SiR/0.76 /1.14 /1.52 /2.03	1,2,5

### Notes:

- 1. Insulation in all colours, except clear and transparent.
- 2. Jacket in all colours, except clear and transparent.
- 3. Optional glass fibre covering.
- 4. Flame classification FT1, FT2.
- 5. Flame classification FT2.

DQD 507 Rev. 2004-06-30

Page 2



Certificate: 70214162

Master Contract: 274708

Project: 70214162 Date Issued: February 11, 2019

#### **APPLICABLE REQUIREMENTS**

Class 5835 01:

CSA Standard C22.2 No. 127-95 and 127-18 - Equipment and Lead Wires

Class 5851 01:

CSA Standard C22.2 No. 210-15 – Appliance Wiring Material Products

### **MARKINGS**

The CSA Monogram or the word marked "CSA", the company's identification or tradename/trademark or alternate file number "274708", wire type designation and complete ratings shall bear all the required markings identified in the applicable certification report(s).

DQD 507 Rev. 2004-06-30

Page 3